

**Report on behalf of: CFSCO Construction Fastening Systems Ltd.
339 Agiou Andreou str., Andrea Chambers bldg.
CY-3035 Limassol, Cyprus**

**Suitability of Non-metallic Products for Use in Contact with Water
Intended for Human Consumption with Regard to their Effect on the
Quality of Water British Standard BS6920:2000**

**EPOXY ANCHOR GROUT/MORTAR/ADHESIVE (RED)
(2-part cartridge system)**

The product has satisfied the criteria of WRAS, based on BS6920: Part 1: 2000, "Specification", and thus complies with the requirements of the WRAS Tests of Effect on Water Quality. The sample is suitable for use with cold water only. ALL tests were carried out using a reduced surface area of 1024mm².

Report prepared and authorised by:



R. J. C. Barron
PhD, HSc(I Ions)

Principal Analyst

D. Brown
**BSc(Hons), CChem, MRSC,
IiurChem. MUST**
Pesticides Services Manager

A. C. Moore
BSc(Hons)
Senior Analyst



A. Eaton
BSc(Hons)

Senior Analyst

Submission Date: 10th January, 2006
Report Date: 28th March, 2006
Reference: 27/80997Chemfix



0730